Notice of Exemption

In accordance with section 220 of the Health and Safety at Work Act 2015 (the Act), Halcyon Power Limited is exempted from compliance with regulations 17.17(1)(a) and 17.17(4) of the Health and Safety at Work (Hazardous Substances) Regulations 2017 (the HS Regulations) for the installation at 141 Roscommon Road, Manukau City Centre, Auckland ('the site') used for storing and dispensing hydrogen.

Halcyon Power Limited must -

- (1) aggregate the capacities of the stationary tanks for the purposes of calculating all relevant separation distances, with the separation distances applied from the outermost tank; and
- (2) ensure the stationary tanks are separated from each other by a minimum of 40mm and are positioned to enable visual inspection over the total surface area; and
- (3) ensure flame detection is situated on site such that it would be effective in the case of a hydrogen fire at the stationary tanks; and
- (4) ensure the site is constructed in accordance with 'Hydrogen Fuelling Station Concept Layout Plan Stage 1' (drawing number 02-00, sheet 01, revision K) dated 14/06/2023, unless any proposed deviation from or addition to the concept drawing has been advised to WorkSafe and has been approved by WorkSafe in writing; and
- (5) ensure the stationary tanks comply with Bureau Veritas New Zealand Limited Design Verification Certificate 15667012 issue 3, and the associated drawings; and
- (6) ensure a copy of this exemption is provided to any compliance certifier engaged to issue a location compliance certificate; and
- (7) ensure a copy of this exemption is held at the site.

This exemption takes effect from the date specified in the Gazette notice required by section 221 of HSWA, which will be 13 June 2025 and expires on 13 June 2030 unless it is replaced sooner or revoked. This exemption is given the reference HS2310.

Signed at Wellington this 6th day of June 2025

SHARON THOMPSON Chief Executive

WorkSafe New Zealand